



South Brunswick Township 2022 Water Quality Report

CONTACTS FOR ADDITIONAL INFORMATION

~~~~~

South Brunswick  
Township  
Water Division  
P.O. Box 190  
Monmouth Junction,  
NJ 08852  
Phone 732-329-4000,  
Ext. 7270 (Brian Fusco)

~~~~~

New Jersey Department of
Environmental Protection
Bureau of
Safe Drinking Water
Phone 609-292-5550

~~~~~

United States  
Environmental Protection  
Agency  
Drinking Water Hotline  
Phone 1-800-426-4791

~~~~~

Visit us on the Web at:
www.southbrunswicknj.gov
or the EPA's Safe
Drinking
WaterWeb site at:
www.epa.gov/safewater

~ Public Participation ~

South Brunswick Township meetings will be held either remotely via a web-based video platform or in the meeting room. Remote access to each web-based video platform meeting will be posted 48 hours prior to the meeting on the township website at www.southbrunswicknj.gov under News and Notices. Meetings will be held in the main meeting room of the Municipal building at 540-Ridge Road, Monmouth Junction NJ 08852. Meetings start at 6:00 p.m.

South Brunswick Township PWS ID# 1221004

The water for South Brunswick Township is obtained from deep wells in the Farrington Aquifer which underlies the Dayton area of the Township. The Township also purchases water from the New Jersey American Water Company (NJAW Co.). For more information on New Jersey American Water Co you can go to <https://amwater.com/njaw/> Look for Water Quality Reports from Raritan Area

~ Public Participation ~ Health Information

The sources of both tap and bottled water include rivers, lakes, streams, ponds, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.

The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

Fluoridation of the entire South Brunswick Township water supply went into effect on December 1, 2002. Fluoride levels will be maintained at 0.7 mg/L. You should consult with your pediatrician to make sure this amount is adequate for your child.

Vulnerable Populations Statement:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Contaminants that may be present in source water include:

-  Microbial contaminants - Viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
-  Inorganic contaminants - Salts and metals which can be naturally occurring or result from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
-  Organic chemical contaminants - These include synthetic and volatile organic chemicals which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
-  Radioactive contaminants - Naturally occurring or the result of oil and gas productions and mining operations.
-  Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at www.state.nj.us/dep/swap/ or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550.

The source water assessment performed on our three sources determined the following: Susceptibility ratings for **entry point to the distribution system (EPTDS)**

Table 11: Susceptibility Rating for EPTDS

Contaminant Category

<i>EPTDS ID</i>	<i>EPTDS Name</i>	<i>Well Number</i>	<i>Pathogens</i>	<i>Nutrients</i>	<i>Pesticides</i>	<i>VOCs</i>	<i>Inorganics</i>	<i>Radionuclides</i>	<i>Radon</i>	<i>DBPs</i>
			Rating	Rating	Rating	Rating	Rating	Rating	Rating	Rating
01	Jamesburg Rd WTP Block 31 Lot 35	11/TP	L	H	M	H	M	H	M	H
03	Georges Rd WTP Block 12 Lot 1	13	L	H	M	H	H	H	M	H
05	Broadway Rd WTP Block 1 Lot 15	15	M	M	L	H	L	H	M	M
	Miller Rd WTP Block 6 Lot 4	16	The DEP has not rated Well #16							

Primary Drinking Water Standards ~ 2022

	MCLG	MCL	Maximum Level Detected	Highest Month	Total # of Samples Taken	Compliance Achieved
Total Coliforms	0	5% of monthly samples	0	below 5%	633	Yes

Disinfection By-Products

Parameter	MCLG PPB	MCL PPB	Maximum Level Detected	Detected Range	Highest Running Annual Average	Compliance Achieved
Trihalomethanes	0	80	51.1 PPB	ND -- 51.1 PPB	46.0 PPB	Yes
Five Haloacetic (HAA-5)	0	60	43.1 PPB	ND – 43.1 PPB	32.0 PPB	Yes

2022 disinfection by-products sampling schedule: • **February** – 1st quarter samples are collected for TTHMs and HAA5's. • **May** – 2nd quarter samples are collected for TTHMs and HAA5's • **August** – 3rd quarter samples are collected for TTHMs and HAA5's • **November** – 4th quarter samples are collected for TTHMs and HAA5's. *By product drinking water chlorination.

Nitrate/Nitrites

Parameter	MCLG PPM	MCL PPM	NJAW Co Interconnection	South Brunswick Twsp Well Water	Compliance Achieved
Nitrate	10	10	2.0 PPM	2.2 - 3.9	Yes

*Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider. Source: Runoff from fertilizer use; leaching from septic tanks sewage; erosion of natural deposits.

Radionuclides

Parameter	MCLG	MCL	NJAW Co Interconnection	South Brunswick Twsp Well Water pCi/L	Compliance Achieved
Gross Alpha	0	15 pCi/L	N/A	ND - < 1	Yes
Radium 226 Radium 228 Combined	0	5 pCi/L	N/A	ND - < 1	Yes

*Radionuclides: During 2008, treatment units were installed in Wells #11 and #13 for the removal of Radium 226 and 228. These units went into service in June 2009. Radium 226 & 228: Some people who drink water containing Radium 226 & 228 in excess of the MCL over many years may have an increased risk of incurring cancer.

Lead & Copper

Parameter	MCLG	MCL	South Brunswick Twsp 90th Percentile Detected Level - Jan. - Jun.	South Brunswick Twsp 90th Percentile Detected Level - Jul. - Dec.	Compliance Achieved
Lead	0 PPB	AL = 15 PPB	0 PPB	0 PPB	Yes
Copper	1.3 PPM	AL = 0.13 PPM	0.119 PPM	0.276 PPM	Yes

*Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. South Brunswick Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Call us at 1-732-329-4000 x 7270 to find out how to get your water tested.

Inorganic Chemicals

Parameter	MCLG PPB	MCL	NJAW Co Interconnection, PPB	South Brunswick Twsp Well Water	Compliance Achieved
Arsenic/ppb	0	5	1	N/D	Yes
Barium/ppb	2000	2000	N/A	ND – 43.4 PPB	Yes
Fluoride/ppm	4.0	4.0	ND – 0.6	ND – 0.7 PPM	Yes

*Sources: *Arsenic*: Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes. *Barium*: Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits. *Fluoride*: Added to water at therapeutic levels to maintain concentrations of .5 to .7 ppm. You should be aware that some people who drink water containing arsenic in excess of the new MCL of 5 ppb over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

Perfluorinated Compounds

Contaminants	Unit	NJDEP Guidance Level Ug/L	NJAWCO Highest Result	NJAWCO Range	South Brunswick Running Annual Average	Compliance Achieved
Perfluorooctanoic Acid (PFNA)	ug/L	0.013	N/A	N/A	0.002	Yes
Ethylene Dibromide (EDB)	ug/L	0.05	N/A	N/A	N/D	Yes
Trichloropropane (TCP-1,2,3)	ng/L	0.030	0.006	N/D - 0.006	N/D	Yes
PFOA	ng/L	14 PPT	5	3 to 5	N/D - 7.33	Yes
PFOS	ng/L	13 PPT	4	2 to 4	N/D - 0.57	Yes

Required sampling for these contaminants started in 2021

• Disinfectants	• SBT Annual Average	• SBT Highest Range	• Compliance Achieved
Sodium Hypochlorite	0.99 PPM	1.80 PPM	Yes

Department of Environmental Protection Violations

South Brunswick Township Water Department received a violation from the NJDEP for water quality parameter violation for pH during the 6-month monitoring period from July 2022 to December 2022. Effective July 1st 2022, NJDEP placed South Brunswick Township on Optimal Water Quality Parameter Standards. These standards are more stringent and tightly controlled compared to the previous secondary drinking water standards. The pH at our wells was within the secondary drinking water standards, but not within the Optimal Range which is established by the NJDEP.

If a system is rated highly susceptible for a contamination category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels.

NJDEP found the following potential contaminant sources within the source water assessment areas for our sources:

Pathogens

Disease-causing organisms such as bacteria, protozoa, and viruses. Sources of pathogens include both point and nonpoint activities. An example of a point source of pathogens is a sewer system overflow. An example of a nonpoint source is runoff from areas where livestock are kept.

Nutrients

Common types of nutrients include nitrogen and phosphorous. Nutrients can harm environmental quality, human health, and the efficiency of the drinking water treatment plant by encouraging growth of photosynthetic microorganisms in surface water sources, which alter water characteristics (eutrophic conditions). Sources of nutrients are point and nonpoint sources. Effluents from a sewage treatment plant are a point source of nutrients. Nonpoint sources of nutrients include discharge from septic fields, areas where animal waste is stored, and runoff from agricultural and residential land where fertilizers are used.

Pesticides

Common sources of pesticides include land applications (nonpoint sources) and manufacturing/distribution centers of pesticides (point source). Pesticides are manmade chemicals used to control bacteria, fungi, weeds, rodents, and insects. Examples include herbicides such as atrazine and insecticides such as chlordane.

Synthetic Organic Compounds (SOCs)

Sources of SOCs can be point and nonpoint. Common sources include chemical manufacturing plants, pharmaceutical plants, sewage treatment plants, and discharges from contaminated sites. Synthetic organic compounds are manmade.

Volatile Organic Compounds (VOCs)

Common types of VOCs include chemicals that are used as solvents, degreasers, and gasoline components. VOCs are manmade compounds and are the most common organic contaminants in ground water in New Jersey. Sources of VOCs can be point and nonpoint. Examples of VOCs are methyl tertiary butyl ether (MTBE), benzene and vinyl chloride.

Inorganic

Mineral-based compounds that are both naturally occurring and manmade. Sources of inorganics can be point and nonpoint; common sources include discharges from manufacturing plants, releases from contaminated sites, past land uses, and naturally occurring sources. Inorganic include arsenic, cadmium, copper, lead, mercury, and asbestos.

Radionuclides

Sources of radionuclides can be point and nonpoint; common sources include the decay of naturally occurring minerals, leaching of subsurface material (for example rocks and sedimentary materials) into ground water, and improper disposal of radioactive waste. Radionuclides are a category of contaminant that is both naturally occurring and manmade. Radionuclides are radioactive substances such as radium and radon.

Disinfection Byproduct (DBP) Precursors

Disinfection byproducts are formed when the disinfectants used to kill pathogens during treatment react with dissolved organic material present in the water. A common source of DBP precursors is naturally occurring organic material such as leaves in surface water. The amount of organic matter, the type of disinfectant, the concentration of disinfectant, time of contact, pH, and temperature all have an effect on the concentration of disinfection byproducts produced. Chlorine is the most common disinfectant used in New Jersey.

If you have questions regarding the source water assessment report or summary please contact the Bureau of Safe Drinking Water at swap@dep.state.nj.us or 609-292-5550.

Secondary Drinking Water Standards ~ 2022

These compounds affect aesthetic quality, but do not pose a health risk. (See note*)

Parameter	Recommended Secondary Limits	South Brunswick Township Annually	Compliance Achieved
Iron	0.30 PPM	ND	Yes
Manganese	0.05 PPM	ND-0.34 PPM	Yes
Sodium	50	ND-57.2 PPM	Yes
Sulfate	250 PPM	ND -32.5 PPM	Yes

*Secondary Drinking Water Standards - There are no MCLGs for secondaries. Major Sources: Erosion of natural deposits

South Brunswick Township Water Department has exceeded the Secondary Water standard guidelines that the Department of Environmental Protection sets. The (recommended Upper Manganese Limit) of 0 .05 was exceeded in 2022 in our Dayton Wells. Secondary Standard levels are set for aesthetic reasons and the Department of Environmental Protection agency requires notification to our customers. The Manganese level tested in our wells range from N/D - 0.34 mg /l.

The recommended upper limit for manganese is based on staining of laundry. Manganese is an essential nutrient, and toxicity is NOT expected from high levels which would be encountered in drinking water.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing the arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Abbreviations / Definitions:

Symbol	Definition	Symbol	Definition
<	The results are less than the number listed.	TT	Treatment Technique – A required process intended to reduce the level of a contaminant in drinking water.
≥	The results are greater than or equal to the number listed.	PCi/L	Pico Curie – A unit used to measure radiation.
MCL	Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.	N/A	Not Applicable
MCLG	Maximum Contaminant Level Goal – The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.	ND	Not Detectable at testing limit.
AL	Action Level – The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.	ppb	Parts per billion or micrograms per liter (equates to one day in about 2,729,726 years).
		ppt	Parts per trillion
		ppm	Parts per million or milligrams per liter (equates to one day in about 2,739.7 years).
		MDL	Minimum Detection Limit – The lowest level at which a compound may be detectable.
		USEPA	United States Environmental Protection Agency
		NJDEP	New Jersey Department of Environmental Protection



Make sure all family members know where the main shut-off valve is located in the house and keep this valve accessible. This could prevent serious flooding and property damage if a pipe bursts. For after hours emergency water shut-offs, please call South Brunswick Police at 732-329-4646.




Leaky toilets are one of the biggest causes of high water bills. Periodically, remove the lid from the tank and check the interior parts to assure they are working properly. If the water level is too high, the water can run down the overflow tube wasting water.



South Brunswick Township Water Division
P.O. Box 190
Monmouth Junction, NJ 08852

Make sure all family members know where the main shut-off valve is located in the house and keep this valve accessible. This could prevent serious flooding and property damage if a pipe bursts. For after hours emergency water shut-offs, please call South Brunswick Police at 732-329-4646.



South Brunswick Township 2022 Water Quality Report